

EC TYPE-EXAMINATION CERTIFICATE

MODULE B

IG-300-2011

USCG 164.112/EC0407

This is to certify that the product

EPS NAUTICAL

Reg. (EU) 2021/1158 Item

**MED/3.18a - Surface materials and floor coverings with low
flame-spread characteristics - decorative veneers**

Applicant

PREFORMATI ITALIA S.r.l.

Via Trieste, 26/B - Località Casoni - 36065 MUSSOLENTE (VI) - Italy

it has been submitted to tests identified in the annex to this certificate
in compliance with the module B scheme of directive 2014/90/EU

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved
equipment, which have not been notified to and agreed with Istituto Giordano

Bellaria-Igea Marina - Italy, 3 February 2022

Date of first issue: 6 October 2011

Revision No. 3

Valid until: 5 October 2026

MED Department Technical Manager
(Dott. Ing. Giuseppe Persano Adorno)

Chief Executive Officer

(Dott. Arch. Sara Lorenza Giordano)

Firmato digitalmente da SARA LORENZA GIORDANO

This certificate is made up of 2 pages and remains valid until expiry unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.

Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be reapproved prior to it/they being placed on board vessels to which the amended regulations or standards apply.

This certificate and the documents should be stored for ten years after the last product has been manufactured.


The validity of this certificate is subject to compliance with Istituto Giordano "REG-MED" rules, the Istituto Giordano general conditions of contract for certification and the relevant requirements of Marine Equipment Directive.

The original of this document consists of an electronic document digitally signed pursuant to the applicable Italian Legislation.

Page 1 of 2

Specified standard	IMO Res. MSC.307(88)-(2010 FTP Code), as amended.
Regulation SOLAS 74 as amended	SOLAS 74 Reg. II-2/3, SOLAS 74 Reg. II-2/5, SOLAS 74 Reg. II-2/6, SOLAS 74 Reg. X/3.
Approval documentation	For Klebocem. Test report LAPI No. 1166.4IMO100/11 dated 16 September 2011. Test report LAPI No. 1166.4IMO080/11 dated 16 September 2011. Test report LAPI No. 1166.4IMO100/11 rev. 1 dated 10 July 2014. Test report LAPI No. 1166.4IMO080/11 rev. 1 dated 10 July 2014. For Prefocoll. Test report Istituto Giordano No. 391184 dated 31 January 2022. Test report Istituto Giordano No. 391158 dated 31 January 2022. Test report Istituto Giordano No. 391186 dated 31 January 2022. Test report Istituto Giordano No. 391187 dated 31 January 2022. Technical file No. 90327 rev.00 dated 25 October 2021.
Restrictions	//
Product description	Panel made of polystyrene with a measured density of about 32,5 kg/m ³ , coated on all sides by grey glue/levelling (Klebocem or Prefocoll) with fiberglass net incorporated. Thickness from 30 mm to 350 mm .
Manufacturer	PREFORMATI ITALIA S.r.l. Via Trieste, 26/B - 36065 MUSSOLENTE (VI) - Italy.

Revision legend		
No.	Date	Scope
0	6 October 2011	First issue
3	3 February 2022	Extension Module B for new coating (Prefocoll)

Notes:	
	The mark of conformity ("wheelmark") may only be affixed to the above type approved equipment and a manufacturer's declaration of conformity issued when the production-control phase module (D, E, or F) of annex B of the Directive is fully complied with and controlled by a written inspection agreement with a Notified Body.